

INSPECTA  
EC TYPE-EXAMINATION  
CERTIFICATE

Application of the  
Council Directive 97/23/EC of 29 May 1997 on Pressure Equipment, as amended, and Swedish ordinance AFS 1999:4

CERTIFICATE NO.: 14-1004663-100-1

This Certificate consists of 2 pages

THIS IS TO CERTIFY THAT THE EQUIPMENT

**Safety accessory**

WITH THE TYPE DESIGNATION/EQUIPMENT DESCRIPTION

**Self monitoring pressure limiter type ER-MP**

MANUFACTURED BY

**Elektro Relä AB**

is found to comply with the requirements in Annex I, Essential Safety Requirements  
and EN 12953-9, EN 12952-11

The equipment has been examined with respect to the procedure of conformity assessment as  
described in Module B

APPLICATIONS

Equipment Category: IV

Design Pressure min/max: See limitations bar(g)

Design Temp. range: See limitations °C

Fluid: Steam or hot water


Further details of the product and conditions for the certification are given overleaf.

This Certificate is valid until: 2019-11-14

MÖLNDAL, 2014-11-14

**Inspecta Sweden AB**

Notified Body No.: 0409



Mats Dahlrot

Senior Industrial Surveyor



Notice: The certificate is subject to terms and conditions, if any, overleaf. Any significant changes in design or construction of the product, the quality system or amendments to the AFS 1999:4 (Directive 97/23/EC) or Standards referenced above may render this certificate invalid. The product liability rests with the manufacturer or his representative in accordance with the AFS 1999:4 (Directive 97/23/EC), as amended.

## EC TYPE-EXAMINATION CERTIFICATE

CERTIFICATE NO.: 14-1004663-100-1

### TYPE APPROVAL DOCUMENTS

Risk analyses 2008-12-01

Instruction for function, installation, functional test and maintenance.

Report P903469

Report LVD 0910-007-00

Report EMC 09045

Report ER-MTP:87

Statement 2009-11-16

### SUPPORTING DOCUMENTS

- Operating instructions <sup>1)</sup>

Yes ☒ No ☐

- Risk analysis <sup>1)</sup>

Yes ☒ No ☐

### LIMITATIONS

Pressure limiter

-Pressure 0-400 bar(g) (different set limits will be set from manufacture)

-Temperature -40 to 85 °C

### TESTS CARRIED OUT



On prototype (2009)

### NOTE

This certificate replace certificate 14-798049-01

MÖLNDAL, 2014-11-14

Inspecta Sweden AB

Mats Dahlrot

Senior Industrial Surveyor

### Notes:

1) Items not included in the scope of design review shall be verified by an Inspector of the Notified Body that issues the final certificate.